



Kvalita pitné vody pro pásma se zdrojem: směs Káraný+Želivka
Za období: leden 2025 - červen 2025

Parametr	Jednotka	Průměr	Hygienický limit
Clostridium perfringens	KTJ/100ml	0	max.0 KTJ/100ml MH
Escherichia coli	KTJ/100ml	0	max.0 KTJ(MPN)/100ml NMH
intestinální enterokoky	KTJ/100ml	0	max.0 KTJ/100ml NMH
koliformní bakterie	KTJ/100ml	0	max.0 KTJ(MPN)/100ml MH
počty kolonií při 22°C	KTJ/ml	4	max.300 KTJ/ml MH
počty kolonií při 36°C	KTJ/ml	0	max.100 KTJ/ml MH
mikroskopický obraz - abioseston	%	1	max.5 % MH
mikroskopický obraz - počet organismů	jedinci/ml	0	max.50 jedinci/ml MH
mikroskopický obraz - živé organismy	jedinci/ml	0	max.0 jedinci/ml MH
amonné ionty	mg/l	<0,03	max.0,50 mg/l MH
barva	mg/l Pt	2	max.20 mg/l Pt MH
bromičnany	µg/l	<1,0	max.10 µg/l NMH
dusičnany	mg/l	26,4	max.50 mg/l NMH
dusitany	mg/l	0,01	max.0,50 mg/l NMH
fluoridy	mg/l	0,11	max.1,5 mg/l NMH
hořčík	mg/l	7,1	20 - 30 mg/l DH
chlor volný	mg/l	0,06	max.0,30 mg/l MH
chlorečnany + chloritany (suma)	µg/l	13,5	max.250 µg/l NMH
chlorečnany	µg/l	13,5	max.250 µg/l NMH
chloridy	mg/l	28,3	max.250 mg/l MH
chloritany	µg/l	<10,0	max.250 µg/l NMH
chuť	°	2	max.2 ° MH
KNK 4.5	mmol/l	2,80	
konduktivita	mS/m	54,3	max.125 mS/m MH
kyanidy celkové	mg/l	<0,010	max.0,050 mg/l NMH
pach	°	2	max.2 ° MH
pH - reakce vody	-	7,36	6,5 - 9,5 - MH
sířany	mg/l	63,4	max.250 mg/l MH
suma pesticid. látek bez nerelevantních	ng/l	17,2	max.500 ng/l NMH
teplota vody	°C	10,1	8,0 - 12,0 °C DH
TOC - celkový organický uhlík	mg/l	1,52	max.5,0 mg/l MH
vápník	mg/l	77,3	40 - 80 mg/l DH
vápník a hořčík	mmol/l	2,22	2 - 3,5 mmol/l DH
zákal	ZFn	0,51	max.5 ZFn MH
železo	mg/l	0,03	max.0,20 mg/l MH

Parametr	Jednotka	Průměr	Hygienický limit
antimon	mg/l	<0,0010	max.0,01 mg/l NMH
arsen	mg/l	<0,0010	max.0,01 mg/l NMH
beryllium	µg/l	<0,10	max.2,0 µg/l NMH
bór	mg/l	<0,050	max.1,5 mg/l NMH
draslík	mg/l	3,4	1 - 10 mg/l DH
hliník	mg/l	0,011	max.0,20 mg/l MH
chrom	mg/l	<0,0010	max.0,025 mg/l NMH
kadmium	mg/l	<0,00005	max.0,0050 mg/l NMH
mangan	mg/l	0,004	max.0,050 mg/l MH
měď	mg/l	<0,005	max.1 mg/l NMH
nikl	mg/l	0,0011	max.0,02 mg/l NMH
olovo	mg/l	<0,0010	max.0,01 mg/l NMH
rtuť	mg/l	<0,0002	max.0,001 mg/l NMH
selen	mg/l	<0,0010	max.0,02 mg/l NMH
sodík	mg/l	14,2	max.200 mg/l MH
stříbro	mg/l	<0,0010	max.0,025 mg/l NMH
2,4 D (2,4-dichlorfenoxycetová kyselina)	ng/l	<10,0	max.100 ng/l NMH
2,4-DP (dichlorprop)	ng/l	<20,0	max.100 ng/l NMH
2,6-dichlorobenzamid	ng/l	10,2	max.3000 ng/l NMH
acetamiprid	ng/l	<10,0	max.100 ng/l NMH
acetochlor	ng/l	<10,0	max.100 ng/l NMH
acetochlor ESA	ng/l	<20,0	max.100 ng/l NMH
acetochlor OA	ng/l	<20,0	max.100 ng/l NMH
acifluorfen	ng/l	<20,0	max.100 ng/l NMH
alachlor	ng/l	<10,0	max.100 ng/l NMH
alachlor ESA	ng/l	25,1	max.1000 ng/l NMH
alachlor OA	ng/l	<20,0	max.1000 ng/l NMH
atrazin	ng/l	<10,0	max.100 ng/l NMH
atrazin desethyl desisopropyl	ng/l	13,8	max.100 ng/l NMH
atrazin-desethyl	ng/l	<10,0	max.100 ng/l NMH
atrazine desisopropyl	ng/l	<10,0	max.100 ng/l NMH
atrazine-2-hydroxy	ng/l	<10,0	max.2000 ng/l NMH
azoxystrobin	ng/l	<10,0	max.100 ng/l NMH
bentazon	ng/l	<10,0	max.100 ng/l NMH
1-H-Benzotriazol	ng/l	61,3	max.4000 ng/l NMH
1-methyl-1-H-Benzotriazol	ng/l	<20,0	
5-methyl-1-H-Benzotriazol	ng/l	<20,0	max.4000 ng/l NMH
bifenox	ng/l	<50,0	max.100 ng/l NMH
bisfenol A	ng/l	<50,0	max.2500 ng/l NMH
bisfenol B	ng/l	<50,0	
bisfenol S	ng/l	51,4	
Butachlor ESA	ng/l	<20,0	max.100 ng/l NMH
Butachlor OA	ng/l	<20,0	max.100 ng/l NMH
carbendazim	ng/l	<10,0	max.100 ng/l NMH

Parametr	Jednotka	Průměr	Hygienický limit
clomazone	ng/l	<10,0	max.100 ng/l NMH
clopyralid	ng/l	<10,0	max.100 ng/l NMH
clothianidin	ng/l	<10,0	max.100 ng/l NMH
cyanazin	ng/l	<10,0	max.100 ng/l NMH
cyprokonazol	ng/l	<10,0	max.100 ng/l NMH
cyprosulfamide	ng/l	<10,0	max.100 ng/l NMH
DEET - diethyltoluamide	ng/l	<50,0	max.100 ng/l NMH
desmetryn	ng/l	<10,0	max.100 ng/l NMH
diazinon	ng/l	<10,0	max.100 ng/l NMH
difenoconazole	ng/l	<10,0	max.100 ng/l NMH
diflufenican	ng/l	<10,0	max.100 ng/l NMH
dichlorvos	ng/l	<50,0	max.100 ng/l NMH
dimethachlor	ng/l	<10,0	max.100 ng/l NMH
dimethachlor CGA 369873	ng/l	44,9	max.6000 ng/l NMH
dimethachlor ESA	ng/l	<20,0	max.6000 ng/l NMH
dimethachlor OA	ng/l	<20,0	max.6000 ng/l NMH
Dimethachlor - suma metabolitů	ng/l	44,9	max.12000 ng/l NMH
dimethenamid	ng/l	<10,0	max.100 ng/l NMH
dimethenamid ESA	ng/l	<20,0	max.100 ng/l NMH
dimethenamid OA	ng/l	<20,0	max.100 ng/l NMH
dimethoate	ng/l	<10,0	max.100 ng/l NMH
diuron	ng/l	<10,0	max.100 ng/l NMH
ethofumesate	ng/l	<10,0	max.100 ng/l NMH
fenpropimorph	ng/l	<20,0	max.100 ng/l NMH
fenthion	ng/l	<10,0	max.100 ng/l NMH
fluazinam	ng/l	<10,0	max.100 ng/l NMH
Flufenacet	ng/l	<10,0	max.100 ng/l NMH
flufenacet ESA	ng/l	<20,0	max.100 ng/l NMH
flufenacet OA	ng/l	<20,0	max.100 ng/l NMH
fluopicolide	ng/l	<10,0	max.100 ng/l NMH
fluroxypyr	ng/l	<10,0	max.100 ng/l NMH
hexazinon	ng/l	<10,0	max.100 ng/l NMH
chlorfenvinphos	ng/l	<10,0	max.100 ng/l NMH
chloridazon	ng/l	<10,0	max.100 ng/l NMH
chloridazon - suma metabolitů	ng/l	562,5	max.6000 ng/l NMH
chloridazon-desphenyl	ng/l	432,7	max.3000 ng/l SH
chloridazon-methyl-desphenyl	ng/l	129,7	max.3000 ng/l SH
chlorotoluron	ng/l	<10,0	max.100 ng/l NMH
chlorotoluron desmethyl	ng/l	<10,0	max.100 ng/l NMH
chlorpyriphos	ng/l	<10,0	max.100 ng/l NMH
imidacloprid	ng/l	<10,0	max.100 ng/l NMH
isoproturon	ng/l	<10,0	max.100 ng/l NMH
isoproturon-monodesmethyl	ng/l	<10,0	max.100 ng/l NMH
Isoxaflutol benzoic acid	ng/l	<10,0	max.100 ng/l NMH

Parametr	Jednotka	Průměr	Hygienický limit
Isoxaflutol diketonitril	ng/l	<10,0	max.100 ng/l NMH
isoxaflutole	ng/l	<10,0	max.100 ng/l NMH
MCPA	ng/l	<20,0	max.100 ng/l NMH
MCPB	ng/l	<20,0	max.100 ng/l NMH
MCPP (mecoprop)	ng/l	<10,0	max.100 ng/l NMH
mesotrione	ng/l	<10,0	max.100 ng/l NMH
metalaxyl	ng/l	<10,0	max.100 ng/l NMH
metamitron	ng/l	<10,0	max.100 ng/l NMH
metazachlor	ng/l	<10,0	max.100 ng/l NMH
metazachlor ESA	ng/l	74,7	max.5000 ng/l NMH
metazachlor OA	ng/l	29,1	max.5000 ng/l NMH
metformin	ng/l	127,3	max.1000 ng/l MH
metolachlor ESA	ng/l	70,3	max.6000 ng/l NMH
metolachlor OA	ng/l	20,2	max.6000 ng/l NMH
metolachlor (izomery)	ng/l	<10,0	max.100 ng/l NMH
metribuzin	ng/l	<10,0	max.100 ng/l NMH
metribuzin desamino	ng/l	<10,0	max.100 ng/l NMH
Metribuzin desaminodiketo (DADK)	ng/l	<100,0	max.100 ng/l NMH
nicosulfuron	ng/l	<10,0	max.100 ng/l NMH
pethoxamid	ng/l	<10,0	max.100 ng/l NMH
pethoxamid ESA	ng/l	<20,0	max.100 ng/l NMH
PFOA (perfluoroktanová kyselina)	ng/l	<8,5	
PFOS (perfluoroktansulfonová kyselina)	ng/l	8,4	
prometryn	ng/l	<10,0	max.100 ng/l NMH
propachlor	ng/l	<10,0	max.100 ng/l NMH
Propachlor ESA	ng/l	<20,0	max.100 ng/l NMH
Propachlor OA	ng/l	<20,0	max.100 ng/l NMH
Propamocarb	ng/l	<10,0	max.100 ng/l NMH
propazin	ng/l	<10,0	max.100 ng/l NMH
propiconazol	ng/l	<10,0	max.100 ng/l NMH
Prosulfocarb	ng/l	<10,0	max.100 ng/l NMH
quinoxifen (chinoxifen)	ng/l	<10,0	max.100 ng/l NMH
simazin	ng/l	<10,0	max.100 ng/l NMH
tebuconazol	ng/l	<10,0	max.100 ng/l NMH
terbuthylazin	ng/l	<10,0	max.100 ng/l NMH
terbuthylazin-desethyl-2-hydroxy	ng/l	<10,0	max.100 ng/l NMH
terbutryn	ng/l	<10,0	max.100 ng/l NMH
terbutylazin-2-hydroxy	ng/l	10,7	max.100 ng/l NMH
terbuthylazin-desethyl	ng/l	<10,0	max.100 ng/l NMH
thiamethoxam	ng/l	<10,0	max.100 ng/l NMH
Thiencarbazone-methyl	ng/l	<20,0	max.100 ng/l NMH
trinexapac-ethyl	ng/l	<10,0	max.100 ng/l NMH
Tritosulfuron	ng/l	<20,0	max.100 ng/l NMH
1,1,2,2-tetrachlorethen	µg/l	<0,10	max.10 µg/l NMH

Parametr	Jednotka	Průměr	Hygienický limit
1,1,2-trichlorethen	µg/l	<0,10	max.10 µg/l NMH
1,1,1-dichlorethen	µg/l	<0,10	
1,2-dichlorethan	µg/l	<0,10	max.3 µg/l NMH
1,2-dichlorethen	µg/l	0	
benzen	µg/l	<0,10	max.1 µg/l NMH
bromdichlormethan	µg/l	4,85	
bromoform	µg/l	0,56	
cis-1,2-dichlorethen	µg/l	<0,10	
dibromchlormethan	µg/l	3,27	
dichlormethan	µg/l	<0,10	
ethylbenzen	µg/l	<0,10	
chlorbenzen	µg/l	<0,10	
chloroform	µg/l	5,2	max.30 µg/l MH
m- +p-xylen	µg/l	<0,10	
o+m+p-xylen	µg/l	0	
o-xylen	µg/l	<0,10	
styren	µg/l	<0,10	
tetrachlormethan	µg/l	<0,10	
toluen	µg/l	<0,10	
trans-1,2-dichlorethen	µg/l	<0,10	
trihalomethany	µg/l	13,91	max.50 µg/l NMH
vinylchlorid	µg/l	<0,1	max.0,5 µg/l NMH
benzo(g,h,i)perylene	ng/l	<0,5	
benzo(a)pyren	ng/l	<0,5	max.10 ng/l NMH
benzo(b)fluoranten	ng/l	<0,5	
benzo(k)fluoranten	ng/l	<0,5	
fluoranten	ng/l	<2,0	
indeno(1,2,3cd)pyren	ng/l	<0,5	
suma PAU(4)	ng/l	0	max.100 ng/l NMH
aldrin	ng/l	<3,0	max.30 ng/l NMH
dieldrin	ng/l	<3,0	max.30 ng/l NMH
heptachlor	ng/l	<3,0	max.30 ng/l NMH
heptachlorepoxyd	ng/l	<3,0	max.30 ng/l NMH
hexachlorbenzen	ng/l	<3,0	max.100 ng/l NMH
lindan	ng/l	<3,0	max.100 ng/l NMH
methoxychlor	ng/l	<5,0	max.100 ng/l NMH
p,p'-DDE	ng/l	<3,0	max.100 ng/l NMH
p,p'-DDT	ng/l	<3,0	max.100 ng/l NMH
AMPA (aminomethylfosfonová kyselina)	ng/l	<50,0	max.100 ng/l NMH
glyfosát (N-(fosfonomethyl)glycin)	ng/l	<50,0	max.100 ng/l NMH
uran	mg/l	0,0010	max.0,015 mg/l NMH
1H,1H,2H,2H-Perfluorooctanesulfonic acid	ng/l	<10,0	
ADONA (4,8-dioxa-3H-perfluorononan-3-ol)	ng/l	<0,5	
bromdichloroctová kyselina (DCBAA)	µg/l	<2,0	

Parametr	Jednotka	Průměr	Hygienický limit
bromchloroctová kyselina (BCAA)	µg/l	<2,0	
dibromchloroctová kyselina (DBCAA)	µg/l	<2,0	
dibromoctová kyselina (DBAA)	µg/l	<2,0	
dichloroctová kyselina (DCAA)	µg/l	<2,0	
halogenoctové kyseliny (HAA) - suma 5	µg/l	0	max.60 µg/l NMH
halogenoctové kyseliny (HAA) - suma 9	µg/l	0	
monobromoctová kyselina (MBAA)	µg/l	<2,0	
monochloroctová kyselina (MCAA)	µg/l	<2,0	
PFAS suma (20 per- a polyfluorovaných)	ng/l	2,5	max.100 ng/l NMH
PFBA (perfluorobutanová kyselina)	ng/l	<6,0	
PFBS (perfluorobutansulfonová kyselina)	ng/l	1,3	
PFDA (perfluorodekanová kyselina)	ng/l	<1,0	
PFDoDA (perfluorododekanová kyselina)	ng/l	<1,0	
PFDoDS (perfluorododekansulfonová kyselina)	ng/l	<1,0	
PFDS (perfluorodekansulfonová kyselina)	ng/l	<1,0	
PFHpA (perfluoroheptanová kyselina)	ng/l	<2,0	
PFHpS (perfluoroheptansulfonová kyselina)	ng/l	<1,0	
PFHxA (perfluorohexanová kyselina)	ng/l	<2,0	
PFHxDA (perfluorohexadekanová kyselina)	ng/l	<2,0	
PFHxS (perfluorohexansulfonová kyselina)	ng/l	<0,5	
PFNA (perfluorononanová kyselina)	ng/l	<1,0	
PFNS (perfluorononansulfonová kyselina)	ng/l	<1,0	
PFOA, PFNA, PFHxS a PFOS suma	ng/l	1,19	max.10 ng/l SH
PFPA (perfluoropentanová kyselina)	ng/l	<2,0	
PFPS (perfluoropentansulfonová kyselina)	ng/l	<1,0	
PFTeDA (perfluorotetradekanová kyselina)	ng/l	<2,0	
PFTrDA (perfluorotridekanová kyselina)	ng/l	<1,0	
PFTrDS (perfluorotridekansulfonová kyselina)	ng/l	<2,0	
PFUnDA (perfluoroundekanová kyselina)	ng/l	<1,0	
PFUnDS (perfluoroundekansulfonová kyselina)	ng/l	<1,0	
tribromoctová kyselina (TBAA)	µg/l	<2,0	
trichloroctová kyselina (TCAA)	µg/l	<2,0	

Legenda:

Hodnoty uvedené se znaménkem méně než (<) jsou hodnoty pod mezí stanovitelnosti použité analytické metody.

Výpočet průměru při použití mezí stanovitelnosti:

V případě, že ve výpočtu průměru figuruje mez stanovitelnosti, je do výpočtu brána polovina meze stanovitelnosti.

Typ limitu:

DH - doporučená hodnota, MH - mezní hodnota, NMH - nejvyšší mezní hodnota, SH - směrná hodnota

Hygienické limity odpovídají limitům uvedeným ve vyhlášce MZ č. 252/2004 Sb. (Příloha č. 1) a limitním hodnotám uvedeným v Seznamu posouzených nerelevantních metabolitů pesticidů MZ ČR.

Mezní hodnota pro pražskou distribuční síť:

Hygienickou stanicí hl. města Prahy je pro pražskou distribuční síť stanovena mezní hodnota

pro ukazatel počty kolonií při 22 °C (300 KTJ/ml MH) a pro ukazatel počty kolonií při 36 °C (100 KTJ/ml MH),

která není daná vyhl. č. 252/2004 Sb., v platném znění.

Pro ukazatel metformin je Hygienickou stanicí hl. města Prahy pro pražskou distribuční síť stanoven mírnější hygienický limit (1000 ng/l MH), který je odlišný od limitu daného vyhl. č. 252/2004 Sb., v platném znění.

Přepočet jednotek:

$1 \text{ ng/l} = 0,001 \text{ } \mu\text{g/l} = 0,000001 \text{ mg/l}$

Údaje o kvalitě vody reprezentují průměr za danou oblast. U směsí se lokálně může poměr jednotlivých zdrojů lišit.